

KERALA WATER AUTHORITY

Office of the Assistant Engineer,
Quality Control District Lab,
Aluva: 683 101
Ph. / Fax-0484-2623576
Email: qcdlaluva@gmail.com

No. AE-QCDL/9/22-23

Dated: 18.03.2024

From

The Assistant Engineer.

To

The Superintendent
Taluk Head Quarters Hospital
Perumbavoor

Sir,

Sub: Water sample test result-forwarding – Reg.

Ref: Letter No. Nil dt. 11.03.2024 & Application ID-.QUA_113784 dt 04.03.2024

I am forwarding here with the test result of analysis of water sample in favour of, Amrita Vidyalayam, C/O Geetha Devi P R, Amirta Lane, Perumbavoor handed over to this lab on 11.03.2024.

Acc: As above



Yours faithfully,

A handwritten signature in black ink, appearing to read "Suresh", written over a light grey rectangular background.

ASSISTANT ENGINEER
ASSISTANT ENGINEER
QUALITY CONTROL DISTRICT LAB, EKM
KERALA WATER AUTHORITY
ALUVA



Telephone:0484-2623576
email:qcldaluva@gmail.com

KERALA WATER AUTHORITY



TC-12119

QUALITY CONTROL DISTRICT LAB,ALUVA -683101

WATER TEST REPORT

ULR NO:TC955224000010353F


Report Issue Date: 18.03.2024

Customer Name &Address Amrita Vidyalayam C/O Geetha Devi P R Amirta Lane Perumbavoor	Date of Receipt of Payment	04.03.24
	Date of Sample received	11.03.24
	Sample given by	Customer
	Sample Code	ALY/S/15761/3/24
	Sample Name	Drinking Water
	Sample Condition	Good
	Source of Sample	Well
	Sample Quantity	2 Litre
	Test performing dates :	From : 15.03.24 to 18.03.24

Sl.N	Characteristics	Unit	Test Method	Acceptable Limit as per IS 10500-2012	Result
1	Turbidity	NTU	IS 3025 (Part10)-2023	1.0	0.24
2	pH at 25°C	-	IS 3025 (Part 11)-2022	6.5 to 8.5	6.66
3	Total Hardness (as CaCO3)	mg/L	IS 3025 (Part21)-2009(Reaffirmed 2019)	200	6.1
4	Chloride (as Cl)	mg/L	IS 3025 (Part 32)-1988(Reaffirmed 2019)	250	10.7
5	Iron (as Fe)	mg/L	IS 3025 (Part 53)-2003 (Reaffirmed 2019)	1	BDL(DL=0.1)
6	Nitrate (as NO3)	mg/L	APHA 23rd Edition(UV Screening Method) 2017	45	2.77
7	Electrical conductivity at 25°C	micromhos/cm	IS 3025 (Part 14)-2013(Reaffirmed 2019)	-	75

Remarks:- DL : Detectable Limit
BDL : Below Detectable Limit

- NB:-1) The result stated above related only to the sample(s) submitted for testing by the customer .
2) The samples retain for 15 days from the end date of analysis
3) The test certificate shall not be reproduced except in full without the written approval of the Laboratory



[Signature]

Authorized By
CHEMIST
Quality Control District Lab
Kerala Water Authority
Aluva

End of Report

KWA/QCDL/ALY/01-2020	Issue Date : 04.10.2020
Rev.No-02	Page 1 of 1
Rev.Date : 30/07/2023	



Telephone:0484-2623576
email:-qcldaluva@gmail.co

KERALA WATER AUTHORITY
QUALITY CONTROL DISTRICT LAB,ALUVA -683101
WATER TEST-BACTERIOLOGY REPORT

Report No: KWA/QCDL-A/S/15761/22-23


Report Issue Date: 18.03.2024

Customer Name &Address		Date of Receipt of Payment	04.03.24	
Amrita Vidyalayam C/O Geetha Devi P R Amirta Lane Perumbavoor		Date of Sample received	11.03.24	
		Sample given by	Customer	
		Sample Code	ALY/S/15761/3/24	
		Sample Name	Drinking Water	
		Sample Condition	Good	
		Source of Sample	Well	
		Sample Quantity	200ml	
		Test performing dates :	From : 11.03.24 to 13.03.24	
Sl. No.	Parameter	Acceptable Limit as per IS 10500-2012	Test Method	Result
1	Total Coliform	Shall not be Detected/100ml	IS15185-2016	Present
2	E-Coli	Shall not be Detected/100ml	IS15185-2016	Absent

NB:-1) The result stated above related only to the sample(s) submitted for testing by the customer .

2) The samples retain for 15 days from the end date of analysis

3) The test certificate shall not be reproduced except in full without the written approval of the Laboratory



Authorized By

[Signature]

End of Report

KWA/QCDL/ALY/01-2020		Issue Date : 04.10.2020	
Rev.No: 01	Rev.Date : 02/06/2021	Page 1 of 1	