



DEPARTMENT OF PUBLIC HEALTH AND PREVENTIVE MEDICINE  
**SANITARY CERTIFICATE**  
(Under the Chapter III Rule-24 and appendix-3 of Tamil Nadu Education Rules)




I hereby declare that I have inspected **AMRITA VIDYALAYAM, SF.NO. 733/1A,734/A1 B2 & 735/B2 B2, PUGALUR ROAD, MANMANGALAM VILLAGE, MANMANGALAM (TK), KARUR - 639 006.** Buildings and premises on 07.08.2025 and certify that the accommodation provided for each of the several classes is sufficient for the minimum number of pupils taught therein, and properly ventilated and lighted, that the building is maintained in substantial repair, that it is neat and clean, that the latrine arrangements are adequate and satisfactory, that the supply of drinking water is wholesome adequate and that in all other necessary aspects the sanitation is good.

Sanitary certificate is issued with the following conditions:

- The garbage generated within the building premises should be collected and disposed of properly by appointing required sanitary staff.
- On no account, the garbage should be burnt.
- The occupants should be educated to prevent the usage of plastics within the building premises and no one should bring plastic carry bags, use & throw tumblers to the rooms and should also be educated to keep the surroundings clean.
- Adequate fire safety precautions should be made and NOC should be obtained from fire and Rescue Department.
- There should be a well-trained person in handling the fire extinguisher.
- Adequate Emergency Exit Should be Provided.
- Safe and Protected drinking water alone should be supplied to the children and staffs for consumption.
- The Premises should be inspected periodically for mosquito breeding places and all measures should be taken to keep the premises mosquito free.
- For running a food establishment/canteen, permission should be obtained from the food safety department.
- Incinerator shall be installed for safe disposal of sanitary napkins and consent from pollution Control board should be obtained for installation of incinerator.
- No Smoking board should be displayed at prominent places within the premises.
- In School campus display of sign boards of size 60\*30 cm (No Smoking area/ Smoking here is an offence) inside the institutions.
- Sale of tobacco products should not be permitted within the premises.
- Inform Immediately to the concerned PHC Medical officer/Health Inspector/Block Health Supervisor, as per sec 64 of Tamilnadu Public Health Act, if any notified disease, communicable disease or suspected disease found in the premises,

  
**PRINCIPAL**  
**AMRITA VIDYALAYAM**  
Pugalur Road, Manmangalam Village,  
Manmangalam Taluk,  
Karur District - 639 006.

  
For **AMRITA VIDYALAYAM**  
Correspondent



DEPARTMENT OF PUBLIC HEALTH AND PREVENTIVE MEDICINE  
**SANITARY CERTIFICATE**



(Under the Chapter III Rule-24 and appendix-3 of Tamil Nadu Education Rules)

- As per Tamilnadu government norms institution should provide differently able persons provisions of facilities like ramp, hand rails, toilets anti skid flooring materials and wheel chairs.

**Health Programs implementation**

Institution management should implement the following Health Program's

- Nation Deworming Day (NDD) Programme. (February & August Month of Every Year)
- Rashtriya Bal Swasthya Karyakram (RBSK) Programme.
- Weekly Iron Folic Acid Supplementation (WIFS) Programme.(Every Thursday)
- National Programme for prevention and control of Blindness Control (NPCB)
- National Iodine Deficiency Disorder Control Programme (NIDDCP) and other Programs
- If Tamil Nadu Government declared notified disease under Tamil Nadu Public Health Act, 1939, and notified certain regulations to prevent the outbreak of under the Epidemic Diseases Act, 1897.) The institution should implement the instructions.
- The Certificate issued is liable to be cancelled at any time on infringement of any of the above said conditions and for improper maintenance of sanitation, improper maintenance of the buildings as well as urinals and toilets in the building.
- This certificate is Valid for a Period of One Year from the date of issue
- If Needed Online Certificate Download through this website:  
[www.tnesevai.tn.gov.in](http://www.tnesevai.tn.gov.in)

K.Dis.No. 4692 / E1 / 2025

Dated: 08.2025

Dr. *[Signature]*  
 8.8.2025

Public Health Supervisor  
 District Health Office  
 Karur - 639 007

COUNTER SIGNED



*[Signature]*  
 DISTRICT HEALTH OFFICER  
 KARUR - 639 007.

*[Signature]*  
 8/8/2025

*[Signature]*  
**PRINCIPAL**  
**AMRITA VIDYALAYAM**  
 Pugalur Road, Manmangalam Village,  
 Manmangalam Taluk,  
 Karur District - 639 006.

For **AMRITA VIDYALAYAM**  
*[Signature]*  
 Correspondent

Public Health Supervisor  
 District Health Office  
 Karur - 639 007

PROFORMA REGARDING SAFE DRINKING WATER AND  
SANITARY CONDITION CERTIFICATE


No. 4692/E1/2025

Date 29.08.2025

It is Certified that an inspection team headed by N. Kannan Block Health Supervisor, Government Primary Health Center, Vangal from the Department of Public Health and Preventive Medicine Inspected the AMRITA VIDYALAYAM, Pugalur Road, Manmangalam Village, Manmangalam Taluk, Karur - 639006 on 29.08.2025 and on the Basis of Water Test Report Bearing No. 274/JWA/TWADLab/KRR/2025/Dated.25.08.2025 of Tamilnadu Water Supply and Drainage Board, Karur. Certified that the AMRITA VIDYALAYAM has Safe Drinking Water facilities for the Students and Staffs of the Institution. School is also maintains the hygienic Sanitation Condition in the School Building & the Campus as the norms prescribed by the Central / State / U.T.Govt.

The Certificate is valid till dated of issued from One year

Signature with Seal:

  
29.8.2025

Name:

Block Health Supervisor  
Government Primary Health Centre,  
Vangal-639 116,  
Karur Dist.


Designation:

TO

The Correspondent,  
Amrita Vidyalayam  
Pugalur Road,  
Manmangalam Village,  
Manmangalam Taluk,  
Karur - 639006

  
PRINCIPAL  
AMRITA VIDYALAYAM  
Pugalur Road, Manmangalam Village,  
Manmangalam Taluk,  
Karur - 639006

AMRITA VIDYALAYAM



Correspondent



- TEST WATER BEFORE TASTE -

TAMIL NADU WATER SUPPLY & DRAINAGE BOARD  
DISTRICT LEVEL WATER TESTING LABORATORY

TWAD Board, No 116/1, Bala Arcade, Poonga Nagar, Dindigul Main Road, Thanthonimalai, Karur-639005

TEST REPORT

From Miss M. Bakiyalakshmi ME Junior Water Analyst (I/C) TWAD Board, DWT Lab, Karur	To Amrita Vidyalayam Pugalur Road Manmangalam Karur-639006
---	--

L.No: 274 /JWA/TWAD Lab/KRR/2025/Dated: 25.08.2025

Sir,


Sub: Examination of water sample - Report furnished - Reg.

1) T.O Invoice No. 5752 /dt 18.08.2025 for Rs 1652/-

2) DD.No : 633908/ dt 20.08.2025 Rs 1652 /-IOB,Manmangalam


The results of analysis for the water sample sent under reference is furnished below.

Sample No	274		
Date of Collection	18.08.2025		
Date of Receipt	18.08.2025		
Source	RO Water		
Location of Sampling	In Side The Campus		
Habitation	Pugalur Road		
Panchayat	Manmangalam		
Union	Karur		
Collected by	Customer		
BIS 10500 : 2012	Acceptable limit	Permissible limit in the absence of alternate source	274
<b>I PHYSICAL EXAMINATION</b>			
1 Appearance	--	--	Clear
2 Colour (Pt.Co - scale)	5	15	Colourless
3 Odour	Agreeable	0	None
4 Turbidity NT units	1	5	0
5 Total dissolved solids, mg/L	500	2000	57
6 Electrical conductivity micro mho/cm	--	--	81
<b>II CHEMICAL EXAMINATION</b>			
7 pH	6.5 to 8.5	6.5 to 8.5	7.52
8 Ph-Alkalinity as CaCO <sub>3</sub> mg/L			0
9 Total Alkalinity CaCO <sub>3</sub> mg/L	200	600	12
10 Total Hardness as CaCO <sub>3</sub> mg/L	200	600	23
11 Iron as Fe mg/L	0.3	1.0	0.00
12 Nitrate as NO <sub>3</sub> mg/L	45	45	0
13 Chloride as Cl mg/L	250	1000	18
14 Fluoride as F mg/L	1	1.5	0.0
15 Sulphate as SO <sub>4</sub> mg/L	200	400	0
16 Free residual chlorine mg/L	0.2	1.0	0
<b>III BACTERIOLOGICAL EXAMINATION</b>			
1 Fecal coliform (colonies per 100 ml)	0	0	0
REPORT: 274 The water is <u>Physically</u> , <u>Chemically</u> , <u>Potable</u> and <u>Bacteriologically Not Contaminated</u> with respect to the Tested Parameters.			

  
**PRINCIPAL**  
**AMRITA VIDYALAYAM**  
 Pugalur Road, Manmangalam Village,  
 Manmangalam Taluk,  
 Karur District - 639 006.

For **AMRITA VIDYALAYAM**

  
Correspondent

M.B.  
  
 Junior Engineer  
 TWAD Board - I  
 RWS Sub Division,  
 Karur.